

ABBREVIATIONS LEGEND

AC = ABOVE CEILING	NEC = NATIONAL ELECTRIC CODE
AFF = ABOVE FINISHED FLOOR	NFPA = NATIONAL FIRE PROTECTION ASSOCIATION
AHJ = AUTHORITY HAVING JURISDICTION	NIC = NOT IN CONTRACT
ALM = ALARM	NPU = NETWORK PROCESSING UNIT
ANN = ANNUNCIATOR	NTS = NOT TO SCALE
BMS = BUILDING MANAGEMENT SYSTEM	PAP = PRE-ACTION PANEL
C = CEILING MOUNTED	RC = EXISTING TO REMOVE AND COVER
CD = CANDELA RATING	RD = EXISTING DEVICE TO BE RELOCATED
DET = DETECTOR	RL = RELOCATED DEVICE
DGP = DATA GATHERING PANEL	RR = REMOVE EXISTING & REPLACE WITH NEW
E = EXISTING TO REMAIN	SCC = STATUS COMMAND CENTER
EOL = END OF LINE	SLC = SIGNALING LINE CIRCUIT
EPO = EMERGENCY POWER OFF	SMK = SMOKE
ER = ELEVATOR RECALL	SUPV = SUPERVISORY
FAA = FIRE ALARM ANNUNCIATOR	TAC = TRUEALERT ADDRESSABLE CONTROLLER
FACP = FIRE ALARM CONTROL PANEL	TOS = TOP OF SHAFT
FATC = FIRE ALARM TERMINAL CABINET	TRBL = TROUBLE
FBO = FURNISHED BY OTHERS	TS = TAMPER SWITCH
FCC = FIRE COMMAND CENTER	TYP = TYPICAL
FSD = FIRE SMOKE DAMPER	UON = UNLESS OTHERWISE NOTED
FTR = FIRE ALARM TRANSPONDER	VCC = VOICE COMMAND CENTER
H = HIGH HUMIDITY	VT = VALVE TAMPER
HT = HEIGHT	W = WATTAGE
HVAC = HEATING VENTILATION & AIR CONDITIONING	WI = WITH
IMS = INFORMATION MANAGEMENT SYSTEM	W/O = WITHOUT
MAX = MAXIMUM	WF = WATERFLOW
MIN = MINIMUM	WG = WIRE GUARD
N/A = NOT APPLICABLE	WP = WEATHERPROOF
NAC = NOTIFICATION APPLIANCE CIRCUIT	XP = EXPLOSION PROOF
NDU = NETWORK DISPLAY UNIT	