

All Fire System Piping will be 3/8" schedule 40 black iron.

NC FIRE CODE 904.11.2

System Interconnection:

The Actuation of the fire extinguishing system shall automatically shut down the fuel or electrical power supply to the cooking equipment. The Fuel and electrical supply reset shall be manual.

FUEL SHUTOFF IN FIRE CONDITION  
GAS AND ELECTRICAL TO COOKING APPLIANCES  
WILL SHUT DOWN IN FIRE

